

NOTICE TO BIDDERS

**ADDENDUM TO BID PACKAGE FOR THE TOWNSHIP OF LAKEWOOD NJ
FOR THE NEW INSPECTIONS BUILDING SITE WORK & UTILITIES**

ADDENDUM 1:

NOTICE IS HEREBY GIVEN in response to questions regarding this project.

1. Include an allowance for underground conduit with pull strings. Schedule 80 – 1200 lf. Location to be determined in field.
2. QUESTION: What is to be done with excess soils.
Township: EXCESS Soil to remain bermed on site location to be determined by Township.
3. QUESTION: Conflicting details in fence type
Township: All fencing is to be chain Link 6 foot in height. Disregard “privacy detail pg.9.
4. QUESTION: What type of fencing along Dewey Avenue?
Township: Fence detail along Dewey Avenue is per 4’-6’ High Chain link Fence detail pg. 9.
5. QUESTION: Conflicting detail for Refuse/Recyclable Storage Area Block or Fencing?
Township: Refuse/Recyclable Storage Area is 6 foot chain link enclose with two (2) gates.
6. QUESTION: Proposed fence and Gate Rear detail with gate, is it block wall or fence?
Township: This is 6 foot chain link fence and one (1) chain link gate.

This addendum is now part of the original bid package and has been submitted to all potential bidders in accordance with N.J.S.A. 40A:11-23c. Please access the bid package and addendum at the Lakewood website www.lakewoodnj.gov or by contacting the Purchasing Department at 732-905-5971 or via email at yabraham@lakewoodnj.gov. For any questions, contact the Project Manager, Tony Arcchi, at tarcchi@lakewoodnj.gov or at 732-904-6311. Lauren Kirkman Township Clerk